

Prefire Plan
Lost Roo

ID:

ADDRESS:

1700 Pacific South

Email: roohj@yahoo.com		Phone: 642-8258	FAX:
Contacts: Mark Johnson—360-783-2603 Helen Johnson—360-783-2604			
Assigned Inspector: Glasson			Occupancy Zone: C1
			Assessed Value:
Map Page:	Construction Type: V b	Occupancy Type: A2	
Roof Type: Wood Truss	Roof Type Material: Metal		
Number of Units: 1	Occupancy Load: 200	Year Built: 2009	

Property Use: Restaurant & Bar	Time Normally Occupied: 11:30—01:00
Building Status: Occupied	Critical Infrastructure:
Notes:	
Fire Alarm Panel Location: Kitchen	Master Key Location: None
Gas/LPG Shutoff Location: North Side	Electrical Panel Location: East Center
FD Connections: East Side	Sprinkler Room Location: East Center
Other Location Information:	Basement Present: N/A

Building Height: 35'	Number of Floors: 1.5	Square Feet: 6,000	Length: 126	Width: 40
Water Supply Info: #1—17th & Washington— 750 gpm -2 1/2" Ports Only #2—18th and California—1000 gpm				
Exposure Info:				
Hazmat:				

Building Access: Main Door South Side, Kitchen & office north Side—2nd Story East side

Access Problems: Don't exit the 2nd floor door.

Ventilation Problems: Metal Roofing

Pre-Fire Plan Notes: Fire Department Connection East Side

Fire Protection Systems: Sprinkler system building wide, Dry Chemical over hoods in kitchen.



